

Our ref: HD(BS1)/FGN/1034

Fax No: 3152 2030

Date: 25 April 2017

Tel No: 2129 3659

Shui On Building Contractors limited

13/F, New Kowloon Plaza,

38 Tai Kok Tsui Road

Kowloon, Hong Kong

Attn: Mr. C M Wong

Dear Sirs,

Construction of Public Rental Housing Development


Shek Kip Mei Estate Phases 3, 6 and 7 (Sub-Contract to Contract No. 20150611)

Submission of Material Submission – Fire Hydrant (Ref: MAT-FSWP-2.23)

(FSWP Installation)

I refer to your submission ref: SKM-3,6&7/PJS01450/PM7 for the captioned subject dated 18/4/2017. Please find my reply as attached.

Yours faithfully,



K.W. Siu

(BSE/C6)

For Contract Manager

Encl.

cc	BSI/C7 via BSI/C26	w/e
	Lee Yu Kee	w/e
	BSE/C10	w/e
	File via SBSE/C4	w/e

Item	Components	Brand Name	Model No.	Place of Manufacturer.	Comment
1	80 mm Fire Hydrant	Wah Hung	WH006	PRC	<ol style="list-style-type: none"> 1. In page 3 of test report (reference No.J19615), the dimension 'C' and 'D' of hydrant outlet are not complied with BS requirement, Clarification is required. 2. Reference with HD Approval letter should be provided.
2	80 mm Fire Hydrant with parity valve	Wah Hung	WH007	PRC	No adverse comment.