



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(289/2022)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

6 May 2022

Wah Hung Fire Prevention Equipment Co., Limited  
G/F, No. 129 Tai Nan Street,  
Prince Edward, Kowloon,  
Hong Kong

(Attn.: Mr WONG Tsz Tai)

Dear Sir,

**Approval of “WAH HUNG” Pressure Reducing Valves  
(General Acceptance No. C20220358)**

Your letters dated 21 March 2022 and 12 April 2022 refer.

Having considered the test report ref. BC-SUMMARY-2022-020 issued on 21 February 2022 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Wah Nan Fire Fighting Equipment Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** Wah Hung

**Details of Fitting:** Copper alloy pressure reducing valve

**Model:** WH009

**Size:** 32mm, 40mm, 50mm

**Body Markings:**  PN16 Size in DN 2:1 ←

**Expiry Date:** 8 February 2027



This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)  
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only