




# NUTEK SYSTEMS, LTD.

Unit B, 13/F, Block A, Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong.  
Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com



TITLE : Testing of puddle flange

OUR REFERENCE : J18941B

DESCRIPTION OF SAMPLE : 65mm (2½") Cast iron tank connector (puddle flange) with three nos. of flanges; pressure rating PN16

SAMPLE SUBMITTED BY : Wah Hung Fire Prevention Equipment Co., Ltd  
Unit 14, 9/F Tonic Industrial Centre,  
Blk A, No.26, Kai Cheung Road,  
Kowloon Bay, Kowloon, Hong Kong

MANUFACTURER : Wah Nan Fire Fighting Equipment Co., Ltd

BRAND : Wah Hung

COUNTRY OF ORIGIN : China

ITEM No. : WH026

MODEL : CIF-6524


BODY MARKING : W DN65X600 PN16 BSEN 1092-2

TEST REQUIRED : 1) BSEN1092-2: 1997 (Type 21 integral flange, PN16 Dimensions) and  
2) Hydrostatic pressure test

PERIOD OF TESTS : 30<sup>th</sup> Jun., 2015

**RESULTS:** - (apply only to the sample tested)

## 1. DIMENSIONS (in millimetres)




			Sample	BSEN Requirement (for PN16 integral flange)
Nominal size			65	65
Overall length			611	/
Diameter of middle flange		D1	138.7	/
Thickness of middle flange		T2	11.3	/
Outermost flanges	outside diameter	D	185.5	185 ±4
	pitch circle diameter	K	145	145 ±1
	thickness, including raised face	T1	23.4	20 +4.0 -3.0
	bolt hole diameter	/	19	19 +1.5 -0
	number of bolt hole	/	4 nos.	4 nos.



# NUTEK SYSTEMS, LTD.

Unit B, 13/F, Block A, Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong.  
Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

OUR REFERENCE NO. J18941B (P.2)

 NUTEK SYSTEMS, LTD.  
Certified True Copy

## 2. HYDROSTATIC PRESSURE TEST


	Test pressure (bar)	Duration (s)	Remark
Sample	24	60	Pass

Note : no leakage was detected during the above test.

## 3. SUMMARY OF RESULTS (apply only to the sample tested)

Dimensions - Satisfactory

Hydrostatic pressure test - Satisfactory

Date : 8 APR. 2016 Authorized signature : 

Nutek Systems is a testing agency,  
approved by the Water Authority and  
Government Supplies Department, for  
testing water supply fittings.

WONG K.S., Sunny

( Director )