

Fugro Development Centre 5 Lok Yi Street, Tai Lam Tuen Mun, NT Hong Kong



Client Ref. : --

Report No.: 205153PC200277(3)

Page 1

REPORT ON TESTING OF HYDRANT VALVE

Information Supplied by Client

Client

Wah Hung Fire Prevention Equipment Co., Limited

Address

: G/F, No.129, Tai Nan Street, Prince Edward, Kowloon, Hong Kong

Sample Description

: 80mm Copper alloy single outlet hydrant valve, 3" BSP male inlet and

2 1/2" female instant outlet.

Brand

: WAH HUNG

Country of Origin

: China

Model

: WH006

Body Marking

80 BS5041/1

Manufacturer

: Wah Nan Fire Fighting Equipment Co., Ltd.

Laboratory Information

Lab. Sample I.D.

PC200277/4

Date Received

21 September 2020, 06 October 2020 &

28 November 2020

Date Test Started

: 21 September 2020

Date Test Completed : 02 December 2020

Test Method

BS 5041: Part 1: 1987: BS336: 2010.

BS EN 1982 : 2008 & BS EN 12164 : 2016

Test Results

1. DIMENSIONS

(Clause 9 Figure 5a of 336: 2010)

		Sample (mm)	BS Requirement (mm)	Remark	
Nominal size (mm)		80	-		
Diameter of handwheel (K) (mm)		135	-		
Height of valve	fully open (mm)	224	-		
	fully closed (mm)	203	-		
Minimum wall thickness (mm)		4.5	min.3.1 (BS5154 PN16)	Pass	
Stem diameter		19.05	min.19 (BS5041)		



Fugro Development Centre 5 Lok Yi Street, Tai Lam Tuen Mun, NT Hong Kong

Page 2 of 6

Client Ref. --

Report No. 205153PC200277(3)

	Results	BS Requirement	Remark
A (mm)	22.10	22±0.25	
B (mm)	29.10	29±0.25	
C (mm)	3.0	3±0.25	
D (mm)	60.1	60±0.25	
E (mm)	53.0	53max.	Pass
F (mm)	71.15	71.1±0.1	
G (mm)	74.8	74.8±0.1	
H (mm)	37.0	37±0.25	

2. Water Flow Rate and Outlet Pressure Test

(BS5041 part 1 clause 22)

	Flow Rate (I/S)	Inlet pressure (bar)	Outlet pressure (bar)	Remark
Sample	8.5	4.7	4.2	Pass
3S Requirement	8.5	4.7	≥4	

3. Hydraulic pressure test

(BS5041 part 1 clause 19)

	Body Test		Seat Test			
	Test Pressure (bar)	Duration (min)	Remark	Test Pressure (bar)	Duration (min)	Remark
Sample	22.5	2	Pass	16.5	2	Pass
BS Requirement for low pressure valve	22.5	2	-	16.5	2	-



Fugro Development Centre 5 Lok Yi Street, Tai Lam Tuen Mun, NT Hong Kong Page 3

of

6

Client Ref. :

Report No. :

205153PC200277(3)

4. Chemical Composition (Body)

(BS 5041 : Part 1 : 1987 clause 8)

Testing items	Results	Specification according to BS EN 1982 : 2008 Grade CC491K castings
1. Copper (Cu) content, %	85.6	83.0 - 87.0 1)
2. Nickel (Ni) content, %	0.28	2.0 max.
3. Phosphorus (P) content, %	<0.03	0.10 max.
4. Lead (Pb) content, %	5.0	4.0 - 6.0
5. Tin (Sn) content, %	5.0	4.0 - 6.0
6. Zinc (Zn) content, %	4.3	4.0 - 6.0
7. Aluminium (AI) content, %	<0.01	0.01 max.
8. Iron (Fe) content, %	<0.04	0.3 max.
9. Sulfur (S) content, %	<0.04	0.10 max.
10. Antimony (Sb) content, %	0.06	0.25 max.
11. Silicon (Si) content, %	<0.01	0.01 max.

Remark: 1) Include nickel

Note: Based on the test results of the submitted sample, it is found that the sample complies with the chemical composition specification of BS EN 1982 : 2008 Grade CC491K castings The chemical composition results are obtained from our test report no. 205153EN202858(2)

5. Chemical Composition (Bonnet)

Testing items	Results	Specification according to BS EN 12164 : 2016 Grade CW617N
1. Aluminum (Al) content, %	<0.01	0.05 max.
2. Copper (Cu) content, %	57.3	57.0 – 59.0
3. Nickel (Ni) content, %	<0.08	0.3 max.
4. Lead (Pb) content, %	1.8	1.6 – 2.5
5. Tin (Sn) content, %	0.11	0.3 max.
6. Zinc (Zn) content, %	40.5	Remainder
7. Iron (Fe) content, %	0.17	0.3 max.
Hence, others content, %	<0.2	0.2 max.

Note: Based on the test results of the submitted sample, it is found that the sample complies with the chemical composition specification of BS EN 12164 : 2016 Grade CW617N.

The chemical composition results are obtained from our test report no. 205153EN203033.



Fugro Development Centre 5 Lok Yi Street, Tai Lam Tuen Mun, NT Hong Kong

Page 4

of 6

Client Ref. :

Report No. :

205153PC200277(3)

6. Chemical Composition (Disc)

Testing items	Results	Specification according to BS EN 12164 : 2016 Grade CW617N
1. Aluminum (AI) content, %	<0.01	0.05 max.
2. Copper (Cu) content, %	57.6	57.0 59.0
3. Nickel (Ni) content, %	<0.08	0.3 max.
4. Lead (Pb) content, %	1.9	1.6 – 2.5
5. Tin (Sn) content, %	0.11	0.3 max.
6. Zinc (Zn) content, %	40.1	Remainder
7. Iron (Fe) content, %	0.17	0.3 max.
Hence, others content, %	<0.2	0.2 max.

Note: Based on the test results of the submitted sample, it is found that the sample complies with the chemical composition specification of BS EN 12164: 2016 Grade CW617N. The chemical composition results are obtained from our test report no. 205153EN203033.

7. Chemical Composition (Stem)

Testing items	Results	Specification according to BS EN 12164 : 2016 Grade CW614N
1. Aluminium (Al) content, %	0.02	0.05 max.
2. Copper (Cu) content, %	58.7	57.0 - 59.0
3. Nickel (Ni) content, %	<0.08	0.3 max.
4. Lead (Pb) content, %	2.6	2.5 – 3.5
5. Tin (Sn) content, %	0.18	0.3 max.
6. Zinc (Zn) content, %	38.2	Remainder
7. Iron (Fe) content, %	0.16	0.3 max.
Hence, others content, %	<0.2	0.2 max.

Note: Based on the test results of the submitted sample, it is found that the sample complies with the chemical composition specification of BS EN 12164: 2016 Grade CW614N. The chemical composition results are obtained from our test report no. 205153EN203033.

fugro

FUGRO TECHNICAL SERVICES LIMITED

Fugro Development Centre 5 Lok Yi Street, Tai Lam Tuen Mun, NT Hong Kong

Client Ref. : --

ilentitei. ,

Report No.: 205153PC200277(3)

Page 5 of 6

8. Summary of Results

Dimension -- Pass
Water Flow Rate and Outlet Pressure Test -- Pass
Hydraulic pressure test -- Pass
Chemical Composition (Body) -- Pass
Chemical Composition (Bonnet) -- Pass
Chemical Composition (Disc) -- Pass
Chemical Composition (Stem) -- Pass

Remarks: The test results relate only to the samples tested.

Checked by: Date: -8 DEC 2020

Ng Shu Shing Chris

Assistant Manager (Plumbing Components)



Fugro Development Centre 5 Lok Yi Street, Tai Lam Tuen Mun, NT Hong Kong

Page 6 of 6

Client Ref. : --

Report No.: 205153PC200277(3)



Test Sample



Body Marking



Body Marking

End of Report